

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVRUM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

RECEIVED
8/10/10

ITW Ramset
700 High Grove Boulevard
Glendale Heights, IL 60139

Attn: Dave Jablonski
(800)-726-7386

RESEARCH REPORT: RR 25264
(CSI # 03150)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-2579

REEVALUATION DUE DATE:
September 1, 2012
Issued Date: July 1, 2010
Code: 2008 LABC

GENERAL APPROVAL – Reevaluation - ITW Ramset Trakfast Fasteners

DETAILS

ITW Ramset Trakfast Fasteners are approved when in compliance with the description, use, identification and findings of Report No. ESR-2579 reissued April 1, 2010, of the ICC Evaluation Service, Incorporated. The Report, in its entirety, is attached and made part of this general approval.

The parts of Report No. 2579 marked by the asterisks have been removed by the Los Angeles Building Department from this approval.

The approval is subject to the following conditions:

1. The ITW Ramset Trakfast Fasteners shall not be used to resist seismic loads, except for fasteners used with architectural, electrical, and mechanical components described in Section 13.1.4 of ASCE 7 per condition 8.5 of the attached Evaluation Service Report.
2. The allowable values listed in the tables are for the fasteners only. The connected drywall tracks shall be checked for their capacity.
3. No increase is permitted in the tabulated allowable loads for short duration loading.

RR 25264
Page 1 of 2